

Absolute Energy savings & investment made



Year of commissioning of project	Project Description	Achievement of energy saving per year			Investment incurred Rs. In lakhs
		Electricity	Fuel	Total Saving Rs. In Lakhs	
		Lakh (KWH)	F. oil (KL)		
2011-12	New Pumps under energy audit at chehedi pumping station	2.20	-	8.25	32.00
	BPT inlet pipe reduced by 3.5 mtr	7.49	-	28.08	1.00
	Sub-Total	9.69	-	36.33	33.00
2012-13	New Pumps at Gangapur Dam pumping Station	17.81	-	89.94	320.00
	New Pumps at Gandhinagar WTP	1.17	-	5.90	15.50
	New Pumps at Bara Bunglow WTP	1.27	-	6.41	17.00
	Sub-Total	20.25	-	102.25	352.50
	Grand Total	29.94	-	138.58	385.50